

Customer Ref No. _____

To confirm the validity of the gas operative please contact Gas Safe Register on Tel: 0800 408 5500

GAS SAFETY RECORD

This form allows the recording of the results of the required checks as defined by the Gas Safety (Installation and Use) Regulations. The information recorded on this form does not confirm that the installation was installed by a Registered Installer or that the installation complies with any relevant Building Regulations. Chimneys/flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the chimney/flue integrity, construction and lining has not been carried out.



Registered Business Details REG NO 12375
 Gas operative D. DUNN (Print name)
 Operative licence No. 5544483
 Company REG. MASTER GWT LTD
 Address UNIT 13 FOREST WLD PARK FOREST ROAD, WAINMAN
 Postcode LE16 3HT Tel No. 02085 300 013

Job Address
 Name (Mr/Mrs/Miss/Ms) _____
 Address 42 HOLLY ROAD
 Postcode NORT WYCOMB
 Tel No. 01494

Client Details (if different)
 Name (Mr/Mrs/Miss/Ms) _____
 Address _____
 Postcode _____ Tel No. _____
 Rented accommodation Yes / No
 No. of appliances tested 1

APPLIANCE DETAILS		INSPECTION DETAILS		FLUE PERFORMANCE		APPLIANCE SAFETY	
Location	Appliance type	Make	Model	Landlord's appliance Yes/No/NA	Appliance inspected Yes/No	Flue type OF/RS/FL	Appliance safe to use Yes/No
1 <u>ATTIC</u>	<u>BOILER</u>	<u>ARISTON</u>	<u>ESMB1 E50</u>	<u>YES</u>	<u>YES</u>	<u>RS</u>	<u>YES</u>
2							
3							
4							

DEFECT(S) IDENTIFIED

Operating pressure in mbar or heat input in kW	Initial combustion analyser reading (if applicable)	Final combustion analyser reading (if applicable)	Safety device(s) correct operation Yes/No/NA	Ventilation provision satisfactory Yes/No	Visual condition of chimney/termination satisfactory Yes/No/NA	Flue performance checks Pass/Fail/NA	Appliance serviced Yes/No	Appliance safe to use Yes/No
1 <u>20 m/s</u>	<u>16.2%</u>	<u>16.0%</u>	<u>YES</u>	<u>YES</u>	<u>YES</u>	<u>PASS</u>	<u>YES</u>	<u>YES</u>
2								
3								
4								

Details of work carried out (e.g. Gas safety check, recall, service etc.)
LOW DUNN'S CHIMNEY CARE

Gas installation pipework satisfactory visual inspection Yes/No
 Emergency Control Valve (ECV) accessible Yes/No
 Satisfactory gas tightness test Yes/NA
 Protective equipotential bonding satisfactory Yes/No

Safety Record issued by: D. DUNN
 Print Name: D. DUNN
 Received by: WAINMAN
 Date appliance(s)/chimney(s) checked: 12/11/2016